

U. S. Coast Guard Equipment List

ALL EQUIPMENT LISTED BELOW IS USCG ACCEPTED AND MAY BE USED AS LONG AS IN GOOD AND SERVICEABLE CONDITION
 "Approved" items are approved for manufacture - "Former May Use" items are no longer manufactured

164.007 Structural Insulation

AMERICAN ENERGY PRODUCTS CORP 1175 E GARVEY STREET COVINA CA 91724

164.007/0041/1 APPROVED Type "JN" sprayed fiber approved as meeting Class A-60 requirements in a tamped thickness of 1 3/4 inches

ANSUL FIRE PROTECTION ONE STANTON STREET MARINETTE WI 54143

164.007/0065/0 APPROVED "Fyrefyba", ceramic fiber type, 2 " thick at 5 lb./cu. ft.

ASK CORPORATION 5-5, TSURUMICHUO 2-CHOME TSURUMI-KU, YOKOHAMA 230 JAPAN

164.007/0054/1 APPROVED "ASK Rock Fine Board-N, No. 120" and "No. 150" mineral wool batt type structural insulation.

HOPEMAN BROTHERS, INC 435 ESSEX AVE WAYNESBORO VA 22980

164.007/0071/0 APPROVED "Sigma 100" structural insulation system incorporating a double layer of glass mat gypsum panels.

ISOLATEK INTERNATIONAL 41 FURNACE STREET STANHOPE NJ 07874

164.007/0067/0 APPROVED "Cafco Blaze Shield D C/F" sprayed fiber insulation.

KEUMKANG LTD 1301-4 SEOCHO-DONG SEOCHO-KU SEOUL S KOREA

164.007/0058/0 APPROVED "Hi-Wool" Type W-205 mineral wool, approved as meeting Class A-60 criteria in nominal density of 120 kg per

164.007/0068/0 APPROVED "Hi-Wool Board" mineral wool, approved as meeting Class A-60 criteria in nominal density of 110 kg/cu. meter

OWENS-CORNING ONE OWENS CORNING PARKWAY TOLEDO OH 43659

164.007/0053/0 APPROVED "Paroc" mineral wool type structural insulation approved for use without other insulating material to meet Class A-60

PARTEK CORPORATION P. O. BOX 61 SF-0051 MELSIKI FINLAND

164.007/0069/0 APPROVED Type " PV-F110L" mineral wool.

PREMIER REFRACTORIES AND CHEMICALS, INC. 101 JONESBOROUGH HWY EDWIN TN 37650

164.007/0075/0 APPROVED "Pyroscat FP" foil faced ceramic fiber blankets meeting A-60 criteria in 8 lb/cu.ft (128 kg./cu. m) nominal density

REILLY-BENTON CO, INC 1645 TCHOUPITOU LAS STREET PO BOX 52346 NEW ORLEANS LA 70152

164.007/0072/0 APPROVED "Pelican Fyrinsul CF/FS" and "Pelican Fyrinsul FS" mineral wool type structural insulation approved as meeting Class A-60

164.007/0073/0 APPROVED "Pelican Fyrinsul RPL" mineral nominal wool type structural insulation approved as meeting meet Class A-3

ROCK WOOL MANUFACTURING CO PO BOX 506 LEEDS AL 35094

164.007/0064/0 APPROVED "Delta Marine Board" mineral wool, appr. as meeting A-60 criteria in min. thick. of 2" (50 mm), and nominal density

ROCKWOOL AS HEDEHUSENE DENMARK

164.007/0055/0 APPROVED Rockwool "Marine Firebatts 110" mineral wool type structural insulation.

SCHULLER INTERNATIONAL INC 10100 WEST UTE AVENUE LITTLETON CO 80162

164.007/0070/0 APPROVED "Structo-Guard" amorphous glass blanket type structural insulation in nominal density of 7 1/4 lb/cu. ft. (11

THERMAFIBER LLC 371 WEST MILL STREET P. O. BOX 237 WABASH IN 46992

164.007/0066/0 APPROVED "Cafco Deck Shield C/F", sprayed fiber type, 1-1/2" thick at 13.1 lb./cu. ft.

THERMAL CERAMICS 2102 OLD SAVANNAH ROAD P. O. BOX 923 AUGUSTA GA 30903

164.007/0060/0 APPROVED "Kaowool", ceramic fiber type structural insulation.

U. S. Coast Guard Equipment List

ALL EQUIPMENT LISTED BELOW IS USCG ACCEPTED AND MAY BE USED AS LONG AS IN GOOD AND SERVICEABLE CONDITION
"Approved" items are approved for manufacture - "Former May Use" items are no longer manufactured

164.007/0074/0 APPROVED "FireMaster Blanket", ceramic fiber type structural insulation.

UNIFRAX CORPORATION 2351 WHIRLPOOL STREET NIAGARA FALLS NY 14305

164.007/0059/0 APPROVED "Fiberfax Durablanket", ceramic fiber insulation, appr. in nominal density of 83 kg/cu. m. (5.5 lb/cu. ft.) and mi

USG INTERIORS, INC. 700 N. HIGHWAY 45 LIBERTYVILLE IL 60048

164.007/0040/0 APPROVED "Thermafiber Industrial Felt" Mineral wool insulation approved as meeting Class A-60 requirements.

BABCOCK AND WILCOX INSULATING PRODUCTS DIV 2102 OLD SAVANNAH ROAD PO BOX 923 AUGUSTA GA 30906

164.007/0061/0 FORMER-MAY USE "Sponge with Foil", ceramic fiber type, meeting A-30 criteria at 3 layers, each 1" thick at 1.25 lb./cu. ft.

NICHIAS CORP NO 1-26, 1-CHOME SHIBADAIMON, MINATU-KU TOKYO 105 JAPAN

164.007/0057/0 FORMER-MAY USE "MG Board 150" mineral wool type structural ins. Approved in 50, 100 and 150 mm thickness and nominal d